

SECTION 097200 - WALL COVERINGS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
 - 1. FRP (Fiberglass Reinforced Panels)

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include data on physical characteristics, durability, fade resistance, and flame-resistance characteristics.
- B. Samples for Initial Selection: Manufacturer's standard brochure for color and texture selection.
- C. Maintenance Data: For wall coverings to include in maintenance manuals.

1.4 QUALITY ASSURANCE

- A. Fire-Test-Response Characteristics: Provide wall coverings and adhesives with the following fire-test-response characteristics as determined by testing identical products applied with identical adhesives to substrates per test method indicated below by UL or another testing and inspecting agency acceptable to authorities having jurisdiction.
 - 1. Surface-Burning Characteristics: As follows, per ASTM E 84:
 - a. Flame-Spread Index: 25 or less.
 - b. Smoke-Developed Index: 450 or less.

1.5 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install wall coverings until spaces are enclosed and weatherproof, wet work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- B. Lighting: Do not install wall covering until a lighting level of not less than 15 fc is provided on the surfaces to receive wall covering.

- C. Ventilation: Provide continuous ventilation during installation and for not less than the time recommended by wall-covering manufacturer for full drying or curing.

1.6 EXTRA MATERIALS

- A. Furnish extra materials described below, before installation begins, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Provide two (2) extra panels per each room covering is being installed.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products listed in Part 2 "Wall-Covering Products" Article.
 - a. Sequentia: StructoGlas FRP
 - b. "Or Approved Equal"

2.2 WALL-COVERING PRODUCTS

- A. General: Provide rolls of each type of wall covering from the same run number or dye lot.
- B. FRP (Fiberglass Reinforced Panels):
 - 1. Size: 48 inches by 96 inches by .090 inches
 - 2. Colors, Textures, and Patterns: As selected by Government Design Professional from manufacturer's full range.

2.3 ACCESSORIES

- A. Adhesive: Mildew-resistant, non-staining, strippable adhesive, for use with specific wall covering and substrate application, as recommended in writing by wall-covering manufacturer.
- B. Seam Tape: As recommended in writing by wall-covering manufacturer.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for levelness, wall plumbness, maximum moisture content, and other conditions affecting performance of work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions for surface preparation.
- B. Clean substrates of substances that could impair wall covering's bond, including mold, mildew, oil, grease, incompatible primers, dirt, and dust.
- C. Prepare substrates to achieve a smooth, dry, clean, structurally sound surface free of flaking, unsound coatings, cracks, and defects.
 - 1. Moisture Content: Maximum of 5 percent on new plaster, concrete and concrete masonry units when tested with an electronic moisture meter.
 - 2. Gypsum Board: Prime with primer recommended by wall-covering manufacturer.
- D. Remove hardware and hardware accessories, electrical plates and covers, light fixture trims, and similar items.
- E. Acclimatize wall-covering materials by removing them from packaging in the installation areas not less than 24 hours before installation.

3.3 INSTALLATION

- A. General: Comply with wall-covering manufacturers' written installation instructions applicable to products and applications indicated, except where more stringent requirements apply.
- B. Install seams vertical and plumb at least 6 inches from outside corners and 3 inches from inside corners unless a change of pattern or color exists at corner. No horizontal seams are permitted.
- C. Trim edges and seams for color uniformity, pattern match, and tight closure. Butt seams without any overlay or spacing between strips.

3.4 CLEANING

- A. Remove excess adhesive at finished seams, perimeter edges, and adjacent surfaces.
- B. Use cleaning methods recommended in writing by wall-covering manufacturer.
- C. Replace strips that cannot be cleaned.
- D. Reinstall hardware and hardware accessories, electrical plates and covers, light fixture trims, and similar items.

END OF SECTION 097200