



- SCALE: 1/8" = 1'-0"

## NOTES

ALL DUCTWORK SHALL BE EXTERNALLY WRAPPED

UNIT HEATERS AND CABINET UNIT HEATERS TO HAVE LOCAL THERMOSTAT (NOT CONNECTED TO BMS). LOCATION TO BE COORDINATED WITH END USERS. REUSE EXISTING THERMOSTAT CONDUIT OR PROVIDE SURFACE MOUNTED EMT CONDUIT.

EXISTING JOHNSON CONTROL PANEL TO BE MODIFIED AS REQUIRED FOR NEW HVAC EQUIPMENT

### DRAWING NOTES:

① EXISTING HVAC EQUIPMENT TO REMAIN



### VERIFY SCALE

BAR IS ONE (1) INCH LONG  
ON ORIGINAL DRAWING

A horizontal number line with tick marks at 0 and 1. A vertical line is drawn at the midpoint, 0.5. The region between 0.5 and 1 is shaded black.

BAR IS NOT ONE (1) INCH LONG  
ADJUST SCALE ACCORDINGLY

CONTRACTOR SHALL FIELD VERIFY  
ALL DIMENSIONS.

VARIANCE FROM CONTRACT  
DOCUMENTS NOT PERMITTED  
WITHOUT BUREAU OF ENGINEER

AND ARCHITECTURE APPROVAL

NO.	DESCRIPTION	DATE
	REVISIONS	

COMMONWEALTH OF PENNSYLVANIA  
DEPT. OF MILITARY & VETERAN'S AFFAIRS  
ANNVILLE, PENNSYLVANIA 17003

DESIGN PROFESSIONALS:

OFFICE OF FACILITIES AND ENGINEERING  
BUREAU OF DESIGN AND PROJECT MANAGEMENT  
BLDG. 0-10, FORT INDIANTOWN GAP  
ANNVILLE, LEBANON COUNTY, PENNSYLVANIA

PROJECT NO.:	42190080
--------------	----------

# 19-101 HVAC/LED UPGRADES "NORTH"

AREA 19 - FORT INDIANTOWN GAP  
ANNVILLE, LEBANON COUNTY, PENNSYLVANIA

## HVAC FLOOR PLAN

DRAWN BY	DATE	DRAWING NO.
G. KITA	11 OCT 2000	

CHECKED BY	SCALE	H.2.1

B. TOEVS	AS NOTED	
----------	----------	--