



1. ROOM NOT IN SCOPE, NO WORK IN THIS AREA.
2. THIS ROOM IS NOT CURRENTLY SPRINKLED. CONTRACTOR SHALL FIELD VERIFY FOR NEW WORK PORTION OF PROJECT.
3. CONTRACTOR TO REMOVE ALL EXISTING SPRINKLER HEADS FROM EXISTING CEILING STRUCTURE SPRINKLER BRANCH PIPING, HANGERS AND ALL ASSOCIATED APPURTENANCES FROM THIS ROOM IN THEIR ENTIRETY.
4. DISCONNECT AND REMOVE ALL EXISTING SPRINKLER HEADS IN THIS ROOM. DISCONNECT AND REMOVE EXISTING SPRINKLER BRANCH PIPING AND HANGERS BACK TO BRANCH POINT. PROVIDE LINE SIZED PIPE CAP AT BRANCH CONNECTION.
5. DISCONNECT AND REMOVE EXISTING RISER SERVING FLOOR ABOVE/BELLOW.
6. DISCONNECT AND REMOVE EXISTING SPRINKLER MAIN PIPING, HANGERS, AND ALL ASSOCIATED APPURTENANCES IN THEIR ENTIRETY BACK TO THIS APPROPRIATE LOCATION. PROVIDE LINE SIZED PIPE CAP ON SPRINKLER MAIN.
7. MODIFY EXISTING SPRINKLER HEAD LAYOUT AND BRANCH PIPING FOR PROPOSED CEILING, WALLS, AND FINISHED IN THIS ROOM IN NEW WORK PORTION OF THIS PROJECT. CONTRACTOR SHALL FIELD VERIFY THE EXISTING SPRINKLER BRANCH PIPING LAYOUT AND RE-USE EXISTING IF POSSIBLE.
8. DISCONNECT AND REMOVE EXISTING SPRINKLER BRANCH PIPING, HANGERS, AND ALL ASSOCIATED APPURTENANCES IN THEIR ENTIRETY BACK TO THIS APPROPRIATE LOCATION. PROVIDE LINE SIZED PIPE CAP ON SPRINKLER BRANCH PIPING.
9. DISCONNECT AND REMOVE EXISTING SPRINKLER PIPING, HANGERS, AND ALL ASSOCIATED APPURTENANCES IN THEIR ENTIRETY BACK TO THIS APPROPRIATE LOCATION. EXISTING SPRINKLER MAIN AND SPRINKLER HEADS SERVING EXISTING MECHANICAL ROOM SHALL BE RECONNECTED DURING NEW CONSTRUCTION.



Architectural floor plan of the 10th floor of the World Trade Center. The plan shows the complex layout of the towers, including various rooms, corridors, and structural elements. A specific area in the lower section of the plan is highlighted with a darker shading and labeled "AREA OF WORK" with a line pointing to it.

FP-002