



SECTION 1  
SCALE: 1/4" = 1'-0"



SECTION 2  
SCALE: 1/4" = 1'-0"




SECTION 3  
SCALE: 1/4" = 1'-0"


THE HVAC CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL ELECTRICAL PANEL LOCATIONS (INSIDE ELECTRICAL AND OUTSIDE ELECTRICAL ROOMS) WITH PIPING AND DUCTWORK LAYOUTS PRIOR TO PIPING AND DUCTWORK INSTALLATION. THE HVAC CONTRACTOR SHALL BE RESPONSIBLE FOR MEETING ALL N.E.C. (NATIONAL ELECTRIC CODE) CLEARANCES BEFORE INSTALLING ANY PIPING AND DUCTWORK. THE HVAC CONTRACTOR SHALL BE RESPONSIBLE FOR ANY AND ALL COSTS RESULTING TO REWORKING (REMOVING AND REINSTALLING) PIPING AND DUCTWORK INSTALLED IN CONFLICT WITH ELECTRICAL PANELS/EQUIPMENT CLEARANCES.

### DRAWING NOTES:

1. REFER TO DRAWING H-4 FOR GENERAL PROJECT NOTES.
2. PROVIDE THE MINIMUM REQUIRED SERVICE CLEARANCES FOR ALL EQUIPMENT AS RECOMMENDED BY THE EQUIPMENT MANUFACTURER.
3. COORDINATE AND SCHEDULE ALL WORK IN CONJUNCTION WITH ARCHITECTURAL DRAWINGS AND PHASING PLANS AS REQUIRED TO ACCOMMODATE PROJECT PHASING.
4. REFER TO PROJECT PHASING DRAWING AND SCHEDULE. PROVIDE ALL LABOR AND MATERIAL NECESSARY TO ACCOMMODATE PROJECT PHASING.
5. THE CONTRACTOR WILL PROVIDE ALL CUTTING, PATCHING AND BACKFILL REQUIRED FOR THEIR WORK.
6. ALL ROOFTOP UNITS INSTALLED ON SPRING ISOLATION RAILS MUST HAVE ALL SPRING ISOLATORS LOCATED ON INTERIOR OF UNIT LOCKED DOWN.



CONSOLIDATED  
ENGINEERS  
1022 James Drive  
Leesport, PA 19533  
Tel: 610-916-1600 Fax: 610-916-1610  
Internet: www.consolidatedengineers.com



AEM ARCHITECTS INC.  
3700 PERKIMEN AVENUE, READING, PA 19606-2795  
Phone: 610-779-3620 Fax: 610-779-3622  
www.aem-arch.com

BUILDING SECTIONS - HVAC  
RENOVATIONS TO THE  
REAMSTOWN ELEMENTARY SCHOOL  
COCALICO SCHOOL DISTRICT  
SOUTH REAMSTOWN ROAD, REAMSTOWN, PENNSYLVANIA, LANCASTER COUNTY, PA

ALL DIMENSIONS AND EXISTING CONDITIONS  
SHALL BE CHECKED AND VERIFIED  
BY THE CONTRACTOR AT THE SITE.

JOB NO.: 22011.00  
DRAWN BY: RLC  
DATE: 04.14.23