


GENERAL NOTES

1. ALL ITEMS TO BE CONSIDERED BB#1 UNLESS NOTED OR SHOWN OTHERWISE.
2. ALL PIPING SHALL BE ROUTED AS HIGH AS POSSIBLE UNLESS INDICATED OTHERWISE.
3. ALL REFRIGERANT PIPING INDICATED AS SINGLE LINE FOR CLARITY. FINAL REFRIGERANT PIPING QUANTITY, SIZE AND DESIGN SHALL BE PER MANUFACTURERS RECOMMENDATION.

KEYNOTES

- 1 3/4" HWS&R PIPING UP TO FIRST FLOOR UNLESS OTHERWISE NOTED.
- 2 3/4" HWS&R PIPING CONNECTING TO CABINET UNIT HEATER LOCATED UNDERNEATH STAIRS. REFER TO 3-WAY PIPING DETAIL FOR ADDITIONAL INFORMATION.
- 3 ROUTE ALL REFRIGERANT PIPING IN ARCHITECTURAL BULKHEAD ACROSS CORRIDOR. REFER TO ARCHITECTURAL DRAWINGS FOR ADDITIONAL INFORMATION.
- 4 ROUTE 3/4" HWS&R PIPING TO AHU AS SHOWN
- 5 ROUTE INDEPENDENT 3/4" HWS&R PIPING TO AHU-1 AND AHU-2. A SINGLE SET OF 3/4" PIPES SHOWN FOR CLARITY.



BASEMENT PLAN - NEW WORK - BASE BID 2 - MECHANICAL

Scale: 3/16" = 1'-0"



BASEMENT PLAN - NEW WORK - MECHANICAL

Scale: 3/16" = 1'-0"



09/13/23	ADDENDUM #2
RECORD REVISIONS	
PROFESSIONAL'S SIGNATURE DATE	
UpStreet ARCHITECTS, INC. 541 PHILADELPHIA ST. INDIANA, PA 15701 911 MENOHER BLVD. JOHNSTOWN, PA 15905	
COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF GENERAL SERVICES HARRISBURG, PENNSYLVANIA	
D.G.S. PROJECT No. C-0588-0015 PHASE 1	

VERIFY SCALE

BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING:

0 1

IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY.

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.

LOYSVILLE YOUTH DEVELOPMENT CENTER- RENOVATIONS TO ZIMMERMAN-BINGAMAN (ZB) COTTAGE

DEPARTMENT OF HUMAN SERVICES
 LOYSVILLE, TYRONE TOWNSHIP, PERRY COUNTY, PA

BASEMENT PLAN - NEW WORK - MECHANICAL

DRAWN BY W. MINAHAN	DATE 27 JUNE 2023	SHEET No. M-300
CHECKED BY T. HOVAN	SCALE AS NOTED	