



1

THIRD FLOOR PLAN - NEW WORK - MECHANICAL

Scale: 3/16" = 1'-0"



GENERAL NOTES

1. ALL ITEMS TO BE CONSIDERED BB#1 UNLESS NOTED OR SHOWN OTHERWISE.

KEYNOTES

1. OUTDOOR AIR CONNECTION SERVING AIR HANDLING UNIT.  
2. OFFSET DUCTWORK AS REQUIRED FOR ROUTING OVER ADJACENT DUCTWORK AS INDICATED. OFFSET SHALL BE CONSTRUCTED OF 45° ELBOWS.  
3. PROVIDE DDC CONTROL PANEL TO SERVE EQUIPMENT INDICATED.  
4. DUCTWORK WITH CROSSHATCHING SHALL BE PAINTED YELLOW FOR SAFETY PURPOSES.  
5. PROVIDE DUCT MOUNTED THERMOSTAT ON RETURN DUCTWORK AS INDICATED.  
6. PROVIDE REMOTE DAMPER CONTROL ACCESS PANEL AS INDICATED. REFER TO M-504 FOR ADDITIONAL INFORMATION.

RECORD REVISIONS			
PROFESSIONAL'S SIGNATURE    DATE			
<b>UpStreet</b> ARCHITECTS, INC. 541 PHILADELPHIA ST.    911 MENOHER BLVD. INDIANA, PA 15701    JOHNSTOWN, PA 15905			
COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF GENERAL SERVICES HARRISBURG, PENNSYLVANIA			
D.G.S. PROJECT No. <b>C-0588-0015 PHASE 1</b>			
<b>LOYSVILLE YOUTH DEVELOPMENT CENTER- RENOVATIONS TO ZIMMERMAN- BINGAMAN (ZB) COTTAGE</b> DEPARTMENT OF HUMAN SERVICES LOYSVILLE, TYRONE TOWNSHIP, PERRY COUNTY, PA			
<b>THIRD FLOOR PLAN - NEW WORK - MECHANICAL</b>			
<b>VERIFY SCALE</b>  BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING:  0    1  IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY	CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.	DRAWN BY W. MINAHAN  CHECKED BY T. HOVAN	DATE 27 JUNE 2023  SCALE AS NOTED
	SHEET No.  <b>M-203</b>		