



1 SECOND FLOOR PLAN - NEW WORK - FIRE PROTECTION
Scale: 3/16" = 1'-0"



NOTES:

1. ALL ITEMS TO BE CONSIDERED BB#1 UNLESS NOTED OTHERWISE.
2. REFER TO FP-001 FOR FIRE SUPPRESSION SYMBOLS, ABBREVIATIONS, NOTES AND DETAILS. REFER TO TYPICAL SPRINKLER CONTROL AND TEST VALVE ASSEMBLY DETAIL 'A' ON DRAWING FP-200. (TYPICAL)
3. THE BUILDING SHALL BE FULLY PROTECTED WITH AN AUTOMATIC FIRE SPRINKLER SYSTEM IN ACCORDANCE WITH THE APPLICABLE CONSTRUCTION CODES, NFPA STANDARDS AND THE FACILITY'S INSURANCE CARRIER REQUIREMENTS. THE FIRE SPRINKLERS ARE SHOWN FOR BID PURPOSES ONLY. (TYPICAL)
4. SECOND FLOOR AREA: (WET) FIRE SPRINKLERS 2858 SF ±
5. THE FIRE SUPPRESSION SYSTEM HYDRAULIC DESIGNED, CALCULATED AND SIZED IN ACCORDANCE WITH NFPA 13.
6. APPROVED INSTITUTIONAL TYPE FIRE SPRINKLER HEADS WILL BE FURNISHED AND INSTALLED IN ALL OCCUPIED AND ACCESSIBLE AREAS THROUGHOUT THE FACILITY UNLESS OTHERWISE NOTED AND SCHEDULED. REFER TO SPRINKLER SCHEDULE ON FP-001.

RECORD REVISIONS			
			
PROFESSIONAL'S SIGNATURE DATE			
UpStreet ARCHITECTS, INC. 541 PHILADELPHIA ST. 911 MENOHER BLVD. INDIANA, PA 15701 JOHNSTOWN, PA 15905			
COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF GENERAL SERVICES HARRISBURG, PENNSYLVANIA			
D.G.S. PROJECT No. C-0588-0015 PHASE 1			
LOYSVILLE YOUTH DEVELOPMENT CENTER- RENOVATIONS TO ZIMMERMAN- BINGAMAN (ZB) COTTAGE DEPARTMENT OF HUMAN SERVICES LOYSVILLE, TYRONE TOWNSHIP, PERRY COUNTY, PA			
SECOND FLOOR PLAN - NEW WORK - FIRE			
VERIFY SCALE BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING: 0 1 IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY	CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.	DRAWN BY S. KORMANIK CHECKED BY W. MINAHAN	DATE 27 JUNE 2023 SCALE AS NOTED
	SHEET No. FP-202		