




1 CABLE RUNWAY RACK MOUNTING - PERPENDICULAR DETAIL  
N.T.S.




2 CABLE RUNWAY RACK MOUNTING - PARALLEL DETAIL  
N.T.S.



3 CABLE RUNWAY SINGLE POINT MOUNTING  
N.T.S.




4 CABLE RUNWAY TRAPEZE MOUNTING  
N.T.S.




1. SURFACE MOUNTED CHANNEL MUST BE SECURELY FASTENED INTO THE SLAB, WALL, ETC. SUFFICIENTLY TO CARRY THE LOAD OF THE TRAY AND ITS CONTENTS WITH A SAFETY FACTOR OF 5.
2. ALL CHANNEL, TRAY FITTINGS AND ACCESSORIES ARE TO BE GALVANIZED.

7 LADDER TYPE CABLE RUNWAY WALL MOUNTING DETAIL  
N.T.S.



5 LADDER TYPE CABLE RUNWAY WALL MOUNTING  
N.T.S.

MIN SEPARATION BETWEEN COMMUNICATION AND 120 VAC: 8"  
MIN SEPARATION BETWEEN COMMUNICATION AND 208 VAC: 12"  
MIN SEPARATION BETWEEN COMMUNICATION AND 480 VAC: 24"  
MIN SEPARATION BETWEEN COMMUNICATION AND LIGHT BALLAST: 24"



6 CORRIDOR SLEEVE CROSS SECTION DETAIL  
N.T.S.



301 BRUSH CREEK RD  
WARRENDALE, PA 15086  
412-212-7515

#### VERIFY SCALE

BAR IS ONE (1) INCH LONG  
ON ORIGINAL DRAWING:  
0 1

IF BAR IS NOT ONE (1) INCH LONG,  
ADJUST SCALE ACCORDINGLY

CONTRACTOR SHALL FIELD VERIFY  
ALL DIMENSIONS.  
VARIANCE FROM CONTRACT  
DOCUMENTS NOT PERMITTED  
WITHOUT PROFESSIONAL & BUREAU  
OF CONSTRUCTION APPROVAL.

RECORD REVISIONS		
PROFESSIONAL'S SIGNATURE    DATE		
<b>UpStreet</b> ARCHITECTS, INC. 541 PHILADELPHIA ST.    911 MENOHER BLVD. INDIANA, PA 15701    JOHNSTOWN, PA 15905		
COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF GENERAL SERVICES HARRISBURG, PENNSYLVANIA		
D.G.S. PROJECT No: <b>C-0588-0015 PHASE 1</b>		
<b>LOYSVILLE YOUTH DEVELOPMENT CENTER- RENOVATIONS TO ZIMMERMAN- BINGAMAN (ZB) COTTAGE</b> DEPARTMENT of HUMAN SERVICES LOYSVILLE, TYRONE TOWNSHIP, PERRY COUNTY, PA		
<b>TELECOM DETAILS</b>		
DRAWN BY CF	DATE 27 JUNE 2023	SHEET No. <b>TT-601</b>
CHECKED BY DV	SCALE N.T.S.	