

MECHANICAL PROJECT NOTES

- REFER TO FLOOR PLANS AND AIR SYSTEM RISER DIAGRAMS FOR DUCTWORK SIZES. PROVIDE DUCTWORK WITH EQUIVALENT FRICTION FACTOR AND VELOCITY WHERE CHANGES ARE REQUIRED TO ACCOMMODATE FIELD CONDITIONS. ALL DUCTWORK TO HAVE A MAXIMUM FRICTION FACTOR OF 0.1" PER 100 FT AND A MAXIMUM VELOCITY OF 2000 FEET PER MINUTE AT DESIGN AIRFLOW RATE.
- INSULATION AND ADHESIVE USED ON THIS PROJECT SHALL HAVE A FLAME SPREAD CLASSIFICATION OF NO MORE THAN 25 AND A SMOKE DEVELOPED RATING OF NOT MORE THAN 50.
- ALL MECHANICAL EQUIPMENT AND DUCTWORK SHALL BE CONSTRUCTED AND INSTALLED IN ACCORDANCE WITH THE "SHEET METAL AND AIR CONDITIONING CONTRACTORS NATIONAL ASSOCIATION" (SMACNA) MANUALS
- ALL DUCTWORK SHALL BE GALVANIZED STEEL SHEET FOR 2" CLASS DUCTWORK SYSTEM UNLESS NOTED OTHERWISE IN ACCORDANCE WITH THE LATEST ISSUE OF THE SHEET METAL AND AIR CONDITIONING CONTRACTORS NATIONAL ASSOCIATION (SMACNA) AND THE AMERICAN SOCIETY OF HEATING, REFRIGERATION AND AIR CONDITIONING ENGINEERS (ASHRAE).
- ALL FLEXIBLE DUCTWORK SHALL BE FLEX MASTER TYPE 4 WITH FACTORY APPLIED UL LISTED MINERAL WOOL INSULATION BLANKET OR APPROVED EQUAL. FLEXIBLE DUCTWORK SHALL NOT EXCEED 5'-0" IN LENGTH.
- ALL CONCEALED DUCTWORK SHALL BE INSULATED WITH 2" EXTERNAL FIBERGLASS INSULATION WITH VAPOR BARRIER, MANVILLE CORPORATION "MICRO-AIRE" OR APPROVED EQUAL.
- PIPING SHALL BE INSTALLED IN ACCESSIBLE AREAS, IN CASES WHERE THE PIPING WILL EXTEND THROUGH A SUPPORTING WALL, PERMANENT CEILING OR FLOOR, SLEEVES MUST BE INSTALLED WITH A UL RATING TO MATCH WALL RATING.
- ALL DUCTWORK JOINTS SHALL BE SEALED AND CAULKED. DUCTWORK SYSTEM SHALL HAVE A MAXIMUM OF 2% LEAKAGE.
- ALL DUCTWORK SIZES ARE INTERNAL FREE AREA.
- ALL SUPPLY, RETURN, & EXHAUST ELBOWS TO HAVE DOUBLE WIDTH TURNING VANES.
- PROVIDE ALL DUCTWORK OFFSETS AS REQUIRED TO ACCOMMODATE NEW LAYOUT FOR A FULLY FUNCTIONAL SYSTEM, COORDINATE WITH EXISTING CONDITIONS.
- PROVIDE INCREASERS/REDUCERS AND ACCESS DOORS ON BOTH SIDES OF ALL REHEAT COILS/VAV BOXES.
- BALANCE ALL MECHANICAL SYSTEMS USING A CERTIFIED NEBB BALANCER.
- PENETRATIONS TO FIRE RATED WALLS, FLOORS, PARTITIONS OR SLABS SHALL BE FILLED & SEALED W/FIRE SEALANT CREATING A FIRE STOP EQUAL TO OR EXCEEDING FIRE RATING OF CONSTRUCTION MATERIAL BEING PENETRATED. FIRE SEALANT SHALL PREVENT SPREAD OF FLAME, SMOKE, AIR, & WATER, & SHALL PASS A 3 HOUR TEST PER ASTM E814 & U.L. 1479. FIRE SEALANT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S WRITTEN INSTRUCTIONS.
- ALL FIRE DAMPERS SHALL BE OF THE LOW LOSS W/DAMPERS OUT OF AIR STREAM (SMACNA TYPE B).
- PROVIDE 1/4" SCALE DUCTWORK & EQUIPMENT SHOP DRAWINGS PRIOR TO START OF WORK. ALL AIR DEVICES TO COORDINATE WITH LIGHTING LAYOUT.
- ALL WORK SHALL BE IN ACCORDANCE WITH LATEST CODES AS ADOPTED BY LOCAL CODE OFFICIAL.
- REFER TO ARCHITECTURAL PLANS FOR FINAL LOCATION/COORDINATION OF ALL FIXTURES, LIGHTS, SPRINKLER HEADS, AIR DEVICES, & ALL MPE & FP ITEMS.
- ALL ABBREVIATIONS AND SYMBOLS MAY NOT APPEAR ON THE DRAWINGS.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR CEILING TYPES, PROVIDE APPROPRIATE FRAMES AND MOUNTING HARDWARE FOR ALL AIR DEVICES. MECHANICAL CONTRACTOR IS RESPONSIBLE FOR COORDINATING ALL MOUNTING DETAILS AND REQUIREMENTS WITH CEILING CONTRACTOR.
- LOCATE ALL PIPING AND DUCTWORK AS HIGH AS POSSIBLE. COORDINATE EXACT LOCATION AND ROUTING WITH ALL OTHER TRADES.
- ROUTE EQUIPMENT DRAIN PIPING TO FLOOR DRAINS TO PREVENT TRIPPING HAZARDS. DO NOT INSTALL PIPING ON FLOOR IN ANY EQUIPMENT ACCESS AISLES.
- PIPING AND DUCTWORK DRAWINGS ARE DIAGRAMMATIC. PROVIDE ADDITIONAL OFFSETS AS REQUIRED TO COORDINATE WITH OTHER TRADES.
- NO PIPING OR DUCTWORK FOREIGN TO ELECTRICAL, TELEPHONE, DATA, OR ELEVATOR MACHINE ROOMS IS PERMITTED TO BE INSTALLED IN THESE SPACES.
- MOUNT MOTOR FOR IN-LINE CENTRIFUGAL FANS IN MOST ACCESSIBLE POSITION.
- PROVIDE ALL PIPING, VALVING & EQUIPMENT SHOWN ON FLOW DIAGRAMS AND DETAILS EVEN IF NOT SHOWN ON FLOOR PLANS.
- ACCESS DOORS FOR FIRE DAMPERS INSTALLED IN FLOOR SLABS SHOULD BE LOCATED ON FLOOR ABOVE, UNLESS INDICATED OTHERWISE.
- PROVIDE A VOLUME DAMPER IN BRANCH RUN OUTS (AS CLOSE TO MAIN AS POSSIBLE) TO EVERY AIR DEVICE. PROVIDE CONCEALED DAMPER REGULATORS WHEN INSTALLED ABOVE INACCESSIBLE CEILINGS.
- PROVIDE SHUT-OFF VALVES IN ACCESSIBLE LOCATIONS (AS CLOSE AS POSSIBLE TO TAKE-OFF) FOR ALL BRANCH PIPING SERVING MORE THAN FIVE COILS. IN ALL BRANCH PIPING CONNECTING DIRECTLY TO MAIN SERVICE, IN ALL RISERS, AT CONNECTIONS TO ALL MECHANICAL EQUIPMENT, AND IN ALL BRANCHES LONGER THAN 100 FEET.
- BEFORE ANY EQUIPMENT OR MATERIALS ARE ORDERED, THE CONTRACTORS SHALL PRODUCE CEILING COORDINATION DRAWINGS IN WHICH THE CONTRACTORS FOR ALL TRADES SHALL SHOW PIPING, DUCTWORK, EQUIPMENT, CONDUIT, AND LIGHTING FIXTURE LOCATION, ROUTING, SIZE AND INSTALLATION HEIGHT. ALL CONFLICTS SHALL BE COORDINATED ON THESE PLANS PRIOR TO THE INSTALLATION OF ANY IN OR ABOVE CEILING EQUIPMENT OR UTILITIES.
- COORDINATE WITH ALL TRADES TO MAINTAIN THE MANUFACTURERS' RECOMMENDED ACCESS TO ALL EQUIPMENT AND TO MAINTAIN ACCESS TO ALL VALVES, VOLUME DAMPERS, GAGES AND CONTROL/ELECTRICAL DEVICES. CEILING TILES WHICH CANNOT BE READILY REMOVED WITHOUT DAMAGE (IF DUE TO IN CEILING DEVICES OR ABOVE CEILING OBSTRUCTIONS) SHALL NOT BE CONSIDERED AS A MEANS OF ACCESS.

AIR DEVICE SCHEDULE					
TAG	DESCRIPTION	MANUFACTURER/MODEL	MAX. NC	NOM. FACE SIZE	REMARKS
CD-1	CEILING DIFFUSER	TITUS/TDCA-AA	22	12x12	4-WAY BLOW U.O.W/OBD
CD-2	CEILING DIFFUSER	TITUS/TDCA-AA	22	24x24	4-WAY BLOW U.O.W/OBD
RR-1	RETURN REGISTER	TITUS/35ORS	17	24x24	-
ER-1	EXHAUST REGISTER	TITUS/35ORS	17	10x10	-

NOTES:			
1. REFER TO MECHANICAL PLANS FOR DESIGN CFM'S FOR ALL AIR DEVICES		DIFFUSER NECK & FLEX DUCT SIZE SCHEDULE	
2. CONTRACTOR TO PROVIDE SUBMITTALS TO ARCHITECT & ENGINEER FOR APPROVAL IN ACCORDANCE WITH AIR DEVICE, DIFFUSER NECK AND FLEX DUCT SCHEDULES.		CFM RANGE	ROUND NECK SIZE
3. ALL AIR DEVICES TO BE PROVIDED WITH VOLUME DAMPERS AT TAKE OFF FROM DUCKWORK MAIN FOR FINAL BALANCING.		0-100	6"Ø
		105-195	8"Ø
		200-295	12x12
4. REFER TO ARCHITECTURAL DRAWING FOR CEILING TYPE, PROVIDE MOUNTING FRAMES AS REQUIRED BY CEILING TYPE.		300-450	12x12
		455-530	15x15
5. ALL FLEXIBLE DUCT SIZES TO MATCH NECK SIZE, PROVIDE DRYWALL MOUNTING FRAMES AS REQUIRED.		531-950	18x18
MAXIMUM FLEX DUCT LENGTH NOT TO EXCEED 5'-0"			

DUCTWORK SCHEDULE							
FAN SYSTEM	DUCT MATERIAL	PRESSURE CLASS	INTERNAL LINER		EXTERNAL INSULATION		REMARKS
			TYPE	THICKNESS	TYPE	THICKNESS	
RETURN DUCTWORK	GALVANIZED STEEL	2"	INTERNAL LINER	1"	FIBERGLASS BLANKET	2"	
MEDIUM PRESSURE SUPPLY	GALVANIZED STEEL	3/2"	INTERNAL LINER	1"	FIBERGLASS BLANKET	2"	
LOW PRESSURE SUPPLY	GALVANIZED STEEL	1"	INTERNAL LINER	1/2"	FIBERGLASS BLANKET	2"	
OUTSIDE AIR SUPPLY	GALVANIZED STEEL	1/2"	-	-	FIBERGLASS BLANKET	2"	

- NOTES: 1. PROVIDE INTERNALLY LINED DUCTWORK WHERE SHOWN.
 2. DUCTWORK DOWNSTREAM OF VAV BOXES TO BE LINED FOR THE FIRST 5'-0", THEN EXTERNALLY INSULATED.
 3. ALL DUCTWORK SHALL BE THE SAME CLASS A, EXCEPT FOR RELIEF & TRANSFER DUCTS.
 4. DUCT SIZES SHOWN ARE CLEAR INSIDE DIMENSIONS.
 5. 2" DOUBLE WALL DUCT WITH FRIB-GONED INSER LINES FOR MEDIUM PRESSURE SUPPLY FROM RTU TO RISER. RISERS SHALL BE 1" LINED DUCTWORK. DUCT LOOPS SHALL BE EXTERNALLY WRAPPED AND BE 2" P.C.
 6. MEDIUM PRESSURE SUPPLY DUCTWORK SHALL BE 2" PRESSURE CLASS FROM RTU THRU RISERS. DUCT LOOPS ON THE FLOORS SHALL BE 2" PRESSURE CLASS.

DESIGNATIONS	
	POINT OF CONNECTION BETWEEN NEW WORK AND EXISTING WORK
	POINT BETWEEN EXIST'G WORK TO REMAIN AND EXIST'G WORK TO BE REMOVED.
	EQUIPMENT DESIGNATION EQUIPMENT DESIGNATION EQUIPMENT NUMBER
	SECTION DESIGNATION SECTION LETTER/NUMBER DRAWING SECTION SHOWN
	DETAIL DESIGNATION DETAIL LETTER/NUMBER DRAWING NUMBER CONTAINING DETAIL

- NOTES TO BIDDERS:
- ALL PARTIES USING THESE DOCUMENTS SHALL VERIFY AND BE RESPONSIBLE FOR ALL FIELD DIMENSIONS AND CONDITIONS PRIOR TO PREPARATION OF SPACE PLANNING OR CONSTRUCTION DOCUMENTATION, OR ACTUAL CONSTRUCTION OF ANY AREA.
 - PRIOR TO SUBMISSION TO BID, CONTRACTOR SHALL VISIT PROJECT SITE AND CAREFULLY EXAMINE EXISTING CONDITIONS AND COMPARE THEM WITH ISSUED PLANS. CONTRACTOR TO ADVISE ARCHITECT AND ENGINEERS OF ANY DISCREPANCIES.
 - SUBMITTAL OF BID SHALL INDICATE THAT CONTRACTOR HAS EXAMINED THE SITE, AND HAS INCLUDED ALL REQUIRED ALLOWANCES IN BID. NO ALLOWANCES SHALL BE MADE FOR ANY ERROR RESULTING FROM CONTRACTOR'S FAILURE TO VISIT JOB SITE.


MECHANICAL SYMBOLS	
	NEW DUCTWORK (SIZE INDICATES INTERNAL FREE AREA)
	CONNECT TO EXISTING VERIFY EXACT LOCATION IN FIELD
	MANUFACTURER
	ABOVE FINISHED FLOOR
	UNLESS NOTED OTHERWISE
	VOLTAGE-PHASE-HERTZ
	STATIC PRESSURE
	GALLONS PER MINUTE
	ENTERING
	CONDENSATE
	LEAVING
	NUMBER
	OWNER FURNISHED CONTRACTOR INSTALLED
	THERMOMETER
	NEW CEILING DIFFUSER SUPPLY AIR DEVICE CD-3/100 AIR DEVICE NO. CFM
	NEW RETURN GRILL (REFER TO AIR DEVICE SCHEDULE)
	DIRECTION OF FLOW
	REDUCTION IN DIRECTION OF FLOW
	CAP
	FLEXIBLE CONNECTOR
	EXISTING TO REMAIN
	SUPPLY REGISTER
	RETURN REGISTER
	ELECTRIC HEAT COIL
	MOD
	REBALANCE EXISTING TO CFM'S INDICATED
	VOLUME DAMPER
	FIRE DAMPER WITH ACCESS PANEL
	NUMBER
	FEET PER MINUTE
	NUMBER
	WITH
	AT
	VARIABLE FREQUENCY DRIVE
	FLOOR
	MODULATING MOTORIZED DAMPER
	TYPICAL
	WEATHERPROOF
	VERIFY IN FIELD
	RELOCATE EXISTING
	BACK DRAFT DAMPER
	DYNAMIC HEAD IN FEET OF WATER
	PRESSURE DROP IN FEET OF WATER
	ENTERING WATER TEMPERATURE
	LEAVING WATER TEMPERATURE
	FEET PER MINUTE
	PRESSURE/TEMPERATURE TEST PLUG
	FLEXIBLE CONNECTION
	ACCESS PANEL
	CEILING
	TRANSFER AIR SLEEVE WITH FIRE DAMPER
	THERMOSTAT 48" ABOVE FINISHED FLOOR WITH LOCKABLE COVER (FINAL LOCATION TO BE APPROVED BY OWNER PRIOR TO INSTALLATION)
	FLEXIBLE DUCT
	DOWN
	CUBIC FEET PER MINUTE
	HVAC SMOKE DETECTOR
	FIRE DAMPER

DUCT/EQUIPMENT SYMBOLS	
SINGLE LINE SYMBOLS	DESCRIPTION
	NEW DUCTWORK
	EXISTING DUCTWORK/EQUIPMENT TO REMAIN
	EXISTING DUCTWORK/EQUIPMENT TO BE REMOVED
	NEW THERMOSTAT WIRE
	DROP IN DUCT ELEVATION
	RISE IN DUCT ELEVATION
	MANUAL VOLUME DAMPER
	ACCESS DOOR /ACCESS PANEL
	VANED ELBOW
	90-DEG ELBOW WITH RADIUS/DIAMETER RATIO EQUAL TO OR GREATER THAN 1.5. INSTALL MITERED ELBOW WITH VANES ONLY IF RADIUS ELBOW DOES NOT FIT
	SIDEWALL SUPPLY REGISTER
	RETURN REGISTER/GRILLE
	FLEXIBLE CONNECTION (FC)
	BRANCH DUCT TAKE-OFF
	90 DEG SPLIT (TEE, WITH VANES)
	ROUND DUCT TURNING UP
	ROUND DUCT TURNING DOWN
	RECTANGULAR DUCT TURNING UP
	RECTANGULAR DUCT TURNING DOWN
	FLEXIBLE DUCTWORK
	TRANSITION
	HUMIDIFIER
	TERMINAL UNIT WITH REHEAT
	TERMINAL UNIT
	EXHAUST FAN (IN-LINE TYPE)
	FIRE DAMPER
	COMBINATION FIRE/SMOKE DAMPER
	MOTOR-OPERATED DAMPER
	MOTOR-OPERATED SMOKE DAMPER
	TRANSFER DUCT
	ELECTRIC DUCT HEATER
	HUMIDITY SENSOR, DUCT MOUNTED
	TEMPERATURE SENSOR, DUCT OR PIPE MOUNTED
	PRESSURE SENSOR PIPE MOUNTED
	STATIC PRESSURE SENSOR, DUCT MOUNTED
	SMOKE DETECTOR, DUCT MOUNTED
	THERMOSTAT/TEMP SENSOR, WALL MOUNTED
	HUMIDISTAT, WALL MOUNTED
	FIRESTAT
	DIFFUSER/GRILLE/REGISTER DESIGNATION
	1 HOUR FIRE RATED
	2 HOUR FIRE RATED
	1 HOUR SMOKE BARRIER

THIS DRAWING AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF THE ARCHITECTS, AND MAY NOT BE REPRODUCED WITHOUT THEIR PERMISSION AND UNLESS THE REPRODUCTION CARRIES THEIR NAME AS ARCHITECTS

DUE TO DISTORTION FROM REPRODUCTION PROCEDURES, DIMENSIONS SHALL NOT BE SCALED FROM THE DRAWING. ONLY DIMENSIONS AS SHOWN SHALL BE VALID

CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND CONDITIONS AT THE SITE BEFORE PROCEEDING WITH THE WORK



SCHILLACI ARCHITECTS LTD.
 KYLE SCHILLACI
 717.875.8035
 KSCHILLACI1306@GMAIL.COM

141 N. Reamstown Rd.
 Stevens, PA 17578

WWW.SCHILLACIARCHITECTS.COM

ELIZABETH TOWNSHIP
 Addition / Renovations
 to an Existing Building
 423 Southview Drive
 Lititz, PA 17543

MECHANICAL COVER SHEET

REVISIONS:
 # DATE DESCRIPTION

ISSUED: 03/22/2023

M0.1

TEMPERATURE CONTROL SYSTEM - SEQUENCE OF OPERATIONS						
GAS FIRED ROOFTOP UNITS			EXHAUST FANS			
1. PROVIDE A SPACE SEVEN DAY, ELECTRONIC, PROGRAMMABLE WALL MOUNTED CONTROLLER FOR BOTH HEATING AND COOLING FOR THIS SYSTEM. SPACE SENSOR TO BE MOUNTED IN RETURN AIR DUCTWORK.			OCCUPIED MODE FAN SHALL RUN CONTINUOUSLY UNOCCUPIED MODE, FAN SHALL BE OFF, BASED ON DEMAND OF SEVEN DAY ELECTRONIC PROGRAMMABLE TIME CLOCK.			
OCCUPIED MODE 1. SUPPLY FAN SHALL RUN CONTINUOUSLY 2. OUTSIDE AIR DAMPER SHALL BE OPEN TO MINIMUM POSITION UNLESS OVERRIDDEN BY ECONOMIZER CONTROLS. 3. COMPRESSOR SHALL ENERGIZE ON A CALL FOR COOLING. SHOULD UNIT HAVE MULTIPLE COOLING STAGES, UNIT CONTROLLER SHALL BE CAPABLE OF SEQUENCING STAGES						
UNOCCUPIED MODE 1. DURING THE UNOCCUPIED TIMES THE FAN SHALL CYCLE ON A CALL FOR HEAT AT THE NIGHT SETBACK TEMPERATURE.						

PIPING LEGEND						
SYMBOL	SERVICE	SIZE	MATERIAL	JOINTS	INSULATION	REMARKS
	REFRIGERANT PIPING	ALL	ACR COPPER TYPE "L" HARD	BRAZED	1/2" ARMAFLEX	-
	AC CONDENSATE	ALL	COPPER TYPE "L" HARD	SOLDERED	1/2" FIBERGLASS	-

REFER TO PIPING SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS

IDSG llc.
 Integrated Design Solution Group, LLC
 ENGINEERS OF MECHANICAL PLUMBING & ELECTRICAL SYSTEMS.
 444 E. TOWNSHIP LINE RD.
 PO BOX 1467
 HAVERTOWN, PA 19083
 610-438-0034
 info@idsgsolutionsllc.com

PROFESSIONAL ENGINEER
 ANDREW J. SILVESTRE, PE
 PA PROFESSIONAL ENGINEER NO. PE08433