

ADDENDUM NO. 3

ELIZABETH TOWNSHIP

ADDITION/RENOVATION TO AN EXISTING BUILDING

In accordance with the requirements of the “Instructions to Bidders,” this Addendum shall be attached to and become a part of the Contract Documents for the above-referenced project.

Concerning the Project Manual

1. Section 00010 – **DELETE** and **REPLACE** in its entirety; attached to this Addendum.
2. Section 00300 – **DELETE** and **REPLACE** in its entirety; attached to this Addendum.
3. Section 01030 – **ADD** Section 01030 – Alternates; attached to this Addendum.

Concerning the Drawings


1. Project Drawings – **DELETE** and **REPLACE** in its entirety; attached to this Addendum.

Miscellaneous (Clarifications, Pre-Bid Meeting Minutes etc.)

1. Refer to Architect’s cover sheet for additional comments regarding the Drawings; attached to this Addendum.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPECIFIED PLACE ON THE BID FORM. THE ABSENCE OF THIS ACKNOWLEDGMENT WILL BE CAUSE FOR REJECTION OF THE BID.

MARK J. SCHILLACI, R.A.
KYLE M. SCHILLACI, R.A.
architects



717.951.7466
schillacs@gmail.com
www.schillaciarchitects.com

ELIZABETH TOWNSHIP- Addendum #3

October 16, 2023

Comments:

1. See attached revised A101 with corrected window tags
2. See attached revised sheet E2.0 for added hanging lite fixtures in Meeting Room #112- these fixtures are to be mounted 20" down from the finished ceiling to bottom of fixture
3. There is no below grade damp/waterproofing on this project
4. See details 4 & 5 on sheet A301 for new exterior stair/ramp
5. Roof sheathing is to be 5/8" exterior grade plywood sheathing
6. Fire alarm/data cabling/terminations and equipment is NOT part of this contract and will be handled by the Owner