LIGHTING CONTROL NOTES:

- IN SPACES WITH WALL BOX OCCUPANCY SENSORS SET TO MANUAL ON/AUTOMATIC OFF WITH 5 MINUTES DELAY TO OFF.
- IN SPACES WITH CEILING MOUNTED OCCUPANCY SENSORS AND LOW VOLTAGE WALL STATIONS (WITH OR WITHOUT DIMMING) SET TO MANUAL ON/AUTOMATIC OFF WITH 10 MINUTES DELAY TO OFF.
- IN SPACES WITH CEILING MOUNTED OCCUPANCY SENSORS SET TO AUTOMATIC ON/AUTOMATIC OFF WITH 10 MINUTES DELAY TO OFF.
- IN ADDITION TO REQUIREMENTS ABOVE, IN SPACES WITH DAYLIGHT SENSORS, SET DAYLIGHT SENSORS TO DIM LIGHTS IDENTIFIED BASED ON AVAILABLE DAYLIGHT WITHIN DAYLIGHT ZONE.

SPECIFIC NOTES - ELECTRICAL NEW	
E1	REINSTALL SPEAKER AND RECONNECT TO MATCH EXISTING.
E2	REINSTALL RECEPTACLE AND RECONNECT TO MATCH EXISTING.
E4	REINSTALL CEILING WIRELESS ACCESS POINT AND RECONNECT TO MATCH EXISTING.
E5	CONNECT TO EXISTING LIGHTING CIRCUIT SERVING SPACE.
E6	PROVIDE DEVICE AS SHOWN IN EXISTING BACKBOX.
E15	UTILIZE JANITORS CLOSET TO ROUTE RECEPTACLE BRANCH CIRCUIT FROM FIRST FLOOR TO FAN ROOM ABOVE.
E16	UTILIZE EXISTING PLUMBING CHASE TO ROUTE RTU-6 FEEDER (BASE BIDS NO. 1 AND 2) OR H&V UNIT 6 AND HV6 CU FEEDER (BASE BID NO. 3) AND RECEPTACLE BRANCH CIRCUIT FROM FIRST FLOOR TO FAN ROOM ABOVE.



1 SECOND FLOOR PLAN - ELECTRICAL
1/8" = 1'-0"

2 SECOND FLOOR PLAN - ELECTRICAL HVAC
1/8" = 1'-0"

GRAPHIC SCALE 1/8"=1'-0"
0 20 40 60 80

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.

CENTURY ENGINEERING
A Kleinfelder Company
10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 589-2400
www.centuryeng.com

© 2021 ALL RIGHTS RESERVED

SEAL

NO.	DESCRIPTION	DATE

REVISIONS

MILLERSVILLE UNIVERSITY

MI-1213 PUCILLO HVAC RENOVATION

125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE

SECOND FLOOR PLAN - ELECTRICAL

ISSUE DATE:	11.17.2023	
DRAWN	DESIGNED	CHECKED
SP	SGH	SGH
SCALE	SHEET NO.	
AS NOTED	E-103	
PROJECT NO.		
24000543.001A		