SPECIFIC NOTES - ELECTRICAL NEW	
E7	DUCT DETECTOR FURNISHED BY DIVISION 26, INSTALLED BY DIVISION 20, WIRED TO SHUT DOWN THE UNIT BY DIVISION 20 AND CONNECTED TO THE FIRE ALARM SYSTEM BY DIVISION 26.
E8	CONNECT TO SPARE 20A-1P BREAKER P2A-7.
E9	FURNISH A 20A-1P BREAKER AND INSTALL IN EXISTING SQUARE D NQ PANEL A1C, SPACE 41. CONNECT WITH 2#10, 1#10 G IN 3/4" CONDUIT.
E12	CONNECT TO RECEPTACLE IN FAN ROOM BELOW.
E25	BASE BID NO. 3: REINSTALL EXISTING DISCONNECT SWITCH AND CONNECT CU-6 VIA DISCONNECT SWITCH WITH INTERIOR DISCONNECT SWITCH WITH 3#12, 1#12 G, IN 3/4" CONDUIT.

RTU-4
DD
E7
DD
WP
E12

RTU-2
DD
E7
DD
WP
E8

CU-2

DOAS-1
WP
DD
E7
DD

EF-1
WP
E9
CU-3

RTU-3
E12
WP
DD
E7
DD

RTU-6
ELECTRICAL WORK INDICATED IS PART OF BASE BIDS NO. 1 AND 2 ONLY.
DD
E7
DD
E25
RELOCATED HV#6 CU

RTU-7
ELECTRICAL WORK INDICATED IS PART OF BASE BID NO. 1 ONLY
E8
WP
DD
E7
DD
PROVIDE AS PART OF BASE BID NO. 1

RTU-1
WP
E8
DD
E7
DD

EXISTING HV#7 CU UNDER BASE BIDS NO. 2 AND 3.

1 ROOF PLAN - ELECTRICAL
1/8" = 1'-0"

GRAPHIC SCALE 1/8"=1'-0"
0 20 40 60 80

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.

CENTURY ENGINEERING
A Kleinfelder Company
10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 589-2400
www.centuryeng.com

© 2021 ALL RIGHTS RESERVED

SEAL

NO.	DESCRIPTION	DATE

REVISIONS

MILLERSVILLE UNIVERSITY

MI-1213 PUCILLO HVAC RENOVATION

125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE

ROOF PLAN - ELECTRICAL

ISSUE DATE: 11.17.2023

DRAWN	DESIGNED	CHECKED
SP	SGH	SGH

SCALE: AS NOTED

SHEET NO.: E-105

PROJECT NO.: 24000543.001A