



SPECIFIC NOTES - ELECTRICAL NEW	
E26	<p>EXISTING DEMAND LOAD ON BUILDING IS 858.5KW.</p> <p>BASE BID NO. 1 ESTIMATED DEMAND LOAD: 1,448 KW.</p> <p>BASE BID NO. 2 ESTIMATED DEMAND LOAD: 1,321 KW.</p> <p>BASE BID NO. 3 ESTIMATED DEMAND LOAD: 1,296 KW.</p> <p>ESTIMATED LOAD CALCULATIONS PER NEC WITH EXISTING DEMAND LOAD TIMES 1.25 - EQUIPMENT REMOVED + EQUIPMENT ADDED.</p>

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.



SEARCH

NO.	DESCRIPTION	DATE
REVISIONS		

MILLERSVILLE UNIVERSITY
MI-1213 PUCILLO HVAC RENOVATION
125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE

LOWER LEVEL
FLOOR PLAN -
ELECTRICAL

ISSUE DATE: 11.17.2023		
DRAWN	DESIGNED	CHECKED
SP	SGH	SGH
SCALE		SHEET NO.
AS NOTED		E-101
PROJECT NO.		
24000543.001A		